

Utility: Inframark
1600 Avalon Parkway
Perris, CA 92571

Date: 6-12-23
Tech: TD/AJ

Account No:
Meter Location: Weel # 4
W/S Avalon Prk wy

Size: 8"
Manuf: Water Specialties
Type: FlowCom
Ser No: 20033724-08

Test Port: 2" plug

Isolation Valve: Discharge piping

Pressure: NA psi

Meter Readings:
Meterhead: 1958631 Units: CF x 100
Remote: Units:

Drive Gear NA
Driven Gear NA

TEST BEFORE REPAIR

Test Meter Data				Subject Meter Data							
Test Run Volume Gallons	Test Run Time		Test Flow GPM	Totalizer Units CF x 100		Test Run Volume Gallons	Test Run Time		Meter Flow GPM	Corr. Factor	Corrected Meter Accuracy
	Min.	Sec.		Stop Read	Start Read		Min.	Sec.			
1491.11	2	55.9	508.6	646	644	1496.00	2	55.1	512.6	99.2	100.0

TEST AFTER REPAIR

Drive Gear
Driven Gear

REMARKS: Test results indicate proper meter accuracy.
