

Utility: Inframark
1600 Avalon Parkway
Perris, CA 92571

Date: 6-12-23
Tech: TD/AJ

Account No:
Meter Location: Well # 1
In plant yard

Size: 6"
Manuf: Water Specialties
Type: FlowCom
Ser No: 20030281-6

Test Port: 2" plug

Isolation Valve: Discharge piping

Pressure: NA psi

Meter Readings:

Meterhead: 176786 Units: Gals x 1000

Remote: Units:

Drive Gear NA
Driven Gear NA

TEST BEFORE REPAIR

Test Meter Data				Subject Meter Data							
Test Run Volume Gallons	Test Run Time		Test Flow GPM	Totalizer Units Gals x 1000		Test Run Volume Gallons	Test Run Time		Meter Flow GPM	Corr. Factor	Corrected Meter Accuracy
	Min.	Sec.		Stop Read	Start Read		Min.	Sec.			
998.50	5	9.1	193.8	877	867	1000.00	5	9.0	194.2	99.2	99.4

Drive Gear
Driven Gear

TEST AFTER REPAIR

REMARKS: Test results indicate proper meter accuracy.

Start truck read: 215887.0

End truck read: 225415.0

Total Water Loss: 9528 Gallons