



Test Certification

14812 Hunter Lane
Midway City CA 92655
Phone: 714 450-5929 Fax: 714 829-3103

Serial Number	20030281-6
Test Date	10/29/2019
Record No	1295
P.O. Number	DONNA ANDERSON
Work Order No.	792

Page 1 of 1

Bill to Customer SE-0070692

Site Customer SE-0055383

Inframark Water Infrastructure Operation
1600 Avalon Parkway
Perris CA 92571

Inframark Water (Well # 1)
1600 Avalon Parkway
Perris CA 92571

Flow Meter Totalizer Reading - Gallons

Site Location

Before Test Flow Meter 91245 x 1000

Prover No

Well # 1

After Test Flow Meter 91249 x 1000

PT-001

Meter Manufacture Size and Model

Service Type

Test Cycle

Pipe Diameter

Pipe Area

Water Specialties, 6" Propeller Meter


Test Only

6

28.2744

Technician

Manny



**Customer Meter
Average Accuracy**

99.85%

Pitot Tube Test Data

Customer Meter

Test No.	Pitot Tube Reading	Actual GPM	Totalizer (start)	Totalizer (end)	Net Volume	Net Volume (gallons)	Test Time (mm:ss:hss)	Measured GPM	Accuracy
1	6.4	180.956	91245	91246	1000	1000.00000	05:32:004	180.71	99.86%
2	6.4	180.956	91246	91247	1000	1000.00000	05:32:015	180.67	99.84%
3	6.4	180.956	91248	91249	1000	1000.00000	05:32:018	180.66	99.84%

Additional Information

Test only, no repair or calibration performed.

Approved By:

Manny Moran